

# OLIVEHURST PUBLIC UTILITY DISTRICT MEMORANDUM



DATE : February 26, 2025

TO : John Tillotson, General Manager

FROM: Nicholas Pomeroy, Chief Plant Operator

RE: **Monthly Report of Activities for Board meeting on 3/20/2025**

---

- For the month of January the OPUD Wastewater Treatment Facility had no exceedances of its N.P.D.E.S. permit.
- Plant Staff cleaned the filters and the UV system to keep both systems running efficiently.
- Rio Del Oro Lift station: Staff has been checking all equipment at Rio Del Oro lift station on a regular basis.
- Lift Station 14: Staff has been water flushing bi-weekly at lift station 14. Staff has also been doing a caustic flush on a monthly basis to help alleviate the hydrogen sulfide. Staff is also testing and recording the hydrogen sulfide numbers 2-3 times a week.
- Collection staff did not jet using the Vaccon due to the Vaccon being in the repair shop. They also used the new CCTV system to inspect approximately 3,000ft of the sewer line.
- The Gold Village waste water plant has been running smoothly. There were no violations in January.
- The Hard Rock casino waste water plant has been running well. The fine bubble diffusers were replaced February 19<sup>th</sup>. Two staff members went to a training class on how to work on/rebuild the pumps used at the Hard Rock Casino's waste water treatment plant.
- The OPUD Waste Water Plant processed during the month of January 57.92 million gallons, which is an average of 1.87 MGD flow.
- The Bar Screen went down at OPUD's WWTP. Saveco (the Bar Screen manufacturer) has been on site working on a list of parts needed to get it working.

**If you have any questions my contact info is below.**

**Nicholas Pomeroy**

Chief Plant Operator  
Olivehurst Public Utility District  
Cell (530) 635-8113  
email: [npomeroy@opud.org](mailto:npomeroy@opud.org)