

OLIVEHURST PUBLIC UTILITY DISTRICT MEMORANDUM



DATE : June 30, 2022

TO : John Tillotson, General Manager

FROM: Greg Axline, Chief Plant Operator

RE: **Monthly Report of Activities for Board meeting on 7/21/2022**

- For the month of June, the Wastewater Treatment Facility had no exceedances of its N.P.D.E.S. permit.
- Plant Staff cleaned the filter panels and on the UV system to keep both systems running efficiently.
- Rio Del Oro Lift station; Staff has been checking all equipment at Rio Del Oro lift station on a regular basis.
- Staff has had to put work into looking for I&I problems with the collection system on hold because of short Staff and workload on doing inspections for the District.
- Staff is looking into purchasing an electric Utility truck for the Plant with going through Sourcewell Member pricing.
- Estimated Plant processed for the month of February was 31.1 MG.

If you have any questions my contact info is below.

Gregory P. Axline

Chief Plant Operator
Olivehurst Public Utility District
Phone (530) 743-0843
Cell (530) 812-2270
email: gaxline@opud.org